

CERTIFICATE OF ASSESSMENT	CERTIFICATE No: SFC 22766-03	Page 1 of 1
----------------------------------	-------------------------------------	--------------------

Report Sponsor	Certificate Issue Date	Product Name
TBA Textiles P/L Unit 12, 8 Leighton Place Hornsby, NSW 2077, Australia	22/11/2019	Firefly Titan and Firefly Plus 60

Assessment Report Reference	Test Methods	Report Issue Date	Report Validity Date
22766 R3.0	AS 1530.4:2014	22/11/2019	30/11/2024

Introduction

The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report(s) or Regulatory Information Reports for more information.

Description of Assessed Products

The test specimen is TBA "Firefly Titan" and TBA Firefly Plus 60 installed as a cavity barrier, tested in accordance with AS 1530.4:2014. For a detailed description of the assessed construction, refer to referenced report.

Summary of Assessed Fire Resistance

Firefly Titan and Firefly Plus 60 Fire Barrier

Barrier Material	Height Between Vertical Support of Barrier	FRL
Firefly Titan	6.3m	60/60/60
	3m	-/120/60
Firefly Plus	3m	30/30/30
	3m	-/60/30

For full details of the construction of the assessed system, please refer to the referenced assessment report

- Conditions/Validity**
- THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.
 - Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
 - The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Warringtonfire Aus Pty Ltd	
ABN	81 050 241 524	
Authorisation	Prepared By:	Reviewed By:
	 Rami Aldarwish	 Omar Saad